



Emiliana Serbatoli S.r.l. - Largo Maestri del Lavoro, 40 - 41011 CAMPOGALLIANO (Modena) Italy | P.IVA e C.F. 01499200366
| Tel. +39-059-521911 | Fax +39-059-521919 | emilianaserbatoli.com | info@emilianaserbatoli.it

DECLARATION OF CONFORMITY

(DIRECTIVE 2006/42/CE, Annex IIA) **CE**

Company Name and Address of the Machine Manufacturer

Emiliana Serbatoli Srl
Largo Maestri del Lavoro, 40, 41011 Campogalliano (Modena)
Tel. +39 059 521911 - Fax: +39 059 521919

Name and Address of the Company Authorised to Compile the Technical File

Emiliana Serbatoli Srl
Largo Maestri del Lavoro, 40, 41011 Campogalliano (Modena)
Tel. +39 059 521911 - Fax: +39 059 521919
in the person of Gian Lauro Morselli

DECLARES THAT THE MACHINE

Named:	Tank Fuel
Model:	TF9 /A501C4
Serial Number:	TF86197
Year:	2026
Equipped with:	Piusi Spa Panther56
Power Supply:	230 V 50 Hz

Is compliant to Directive 2006/42/CE, to Directive 2014/35/EU (low voltage) and to the legislative provisions that transpose them.

It is also compliant to the following harmonised standards :

UNI EN 12100:2010;
UNI EN ISO 13849-1:2023;
CEI EN 60204-1:2018

Campogalliano, 29-01-2026
Emiliana Serbatoli Srl

Il legale rappresentante

Gian Lauro Morselli



Emiliana Serbatoi S.r.l. - Largo Maestri del Lavoro, 40 - 41011 CAMPOGALLIANO (Modena) Italy | P.IVA e C.F. 01499200366
| Tel. +39-059-521911 | Fax +39-059-521919 | emilianaserbatoi.com | info@emilianaserbatoi.it

CERTIFICATE OF CONFORMITY TO THE APPROVED PROTOTYPE AND TEST CERTIFICATE

It is certified that the metal container-dispenser for liquid fuels of category "C" named Tank Fuel, built in compliance with the prototype approved by the Ministry of the Interior with DCPST/A7/09594/AT/09189 del 02/07/2021 and its related renewals and extensions, has the following characteristics:

Model	TF9 /A501C4
Serial Number	TF86197
Capacity:	8995
Diameter:	1900
Height:	3000
Manhole:	400
Year:	2026

Equipped with:

- Mechanical overfill prevention valve calibrated to interrupt the fuel flow at 90% of the tank's geometric capacity
- Minimum level pump shut-off switch


AFTER THE PRESSURE TEST

carried out with pressure of not less than 1 kg/cm², resulted to be perfectly watertight.

This certificate is issued for the purposes authorized by law.

Campogalliano, 29-01-2026
Emiliana Serbatoi Srl

Tecnico Collaudatore



Emiliana Serbattoi S.r.l. - Largo Maestri del Lavoro, 40 - 41011 CAMPOGALLIANO (Modena) Italy | P.IVA e C.F. 01499200366
| Tel. +39-059-521911 | Fax +39-059-521919 | emilianaserbattoi.com | info@emilianaserbattoi.it

DECLARATION OF CORRECT INSTALLATION

The company Emiliana Serbattoi Srl
Based in Largo Maestri del Lavoro, 40, 41011 Campogalliano (Modena)
C.F./P.IVA: 01499200366 | C.C.I.A.A. REA n. 220082

DECLARES

that the supplying group


Brand:	Piusi Spa
Model:	Panther56
Year:	2026
Power Supply:	230 V 50 Hz

for which a separate and attached declaration of conformity has been issued by the Manufacturer in accordance with Directive 2006/42/EC, has been installed by us in a workmanlike manner, in full compliance with the instructions provided by the Manufacturer in accordance with point 1.7.4.2 of the same Directive, in a permanent and immovable connection to the container of our construction:

Named:	TF
Model:	TF9 A501C4
Serial Number:	TF86197
Year:	2026

Campogalliano, 29-01-2026
Emiliana Serbattoi Srl

Tecnico Collaudatore



**EMILIANA
SERBATOI**

ADVANCED FUEL SOLUTIONS

Emiliana Serbatoi S.r.l. - Largo Maestri del Lavoro, 40 - 41011 CAMPOGALLIANO (Modena) Italy | P.IVA e C.F. 01499200366
| Tel. +39-059-521911 | Fax +39-059-521919 | emilianaserbatoi.com | info@emilianaserbatoi.it

Tabella centimetrica serbatoio orizzontale

TF9

Capacità effettiva 8.995

Dimensioni:

diametro esterno 1.900 mm

fasciame 3.000 mm

spessore fondi 30/10 mm

spessore fasciame 30/10 mm

Lettura asta	Volume liquido	Lettura asta	Volume liquido	Lettura asta	Volume liquido	Lettura asta	Volume liquido	Lettura asta	Volume liquido
cm	litri	cm	litri	cm	litri	cm	litri	cm	litri
0	0	41	1.443	82	3.815	123	6.363	164	8.517
1	6	42	1.494	83	3.877	124	6.423	165	8.559
2	16	43	1.545	84	3.940	125	6.482	166	8.600
3	30	44	1.597	85	4.002	126	6.542	167	8.640
4	46	45	1.650	86	4.065	127	6.601	168	8.679
5	64	46	1.703	87	4.127	128	6.659	169	8.718
6	84	47	1.756	88	4.190	129	6.718	170	8.756
7	106	48	1.810	89	4.253	130	6.776	171	8.792
8	129	49	1.864	90	4.316	131	6.834	172	8.812
9	154	50	1.919	91	4.378	132	6.892	173	8.830
10	180	51	1.974	92	4.441	133	6.949	174	8.849
11	207	52	2.029	93	4.504	134	7.006	175	8.866
12	236	53	2.085	94	4.567	135	7.063	176	8.882
13	266	54	2.141	95	4.630	136	7.119	177	8.898
14	297	55	2.197	96	4.693	137	7.175	178	8.912
15	329	56	2.254	97	4.756	138	7.231	179	8.925
16	362	57	2.311	98	4.819	139	7.286	180	8.937
17	396	58	2.368	99	4.882	140	7.341	181	8.948
18	431	59	2.426	100	4.944	141	7.396	182	8.957
19	467	60	2.484	101	5.007	142	7.450	183	8.966
20	504	61	2.542	102	5.070	143	7.503	184	8.975
21	542	62	2.600	103	5.133	144	7.557	185	8.980
22	580	63	2.659	104	5.195	145	7.610	186	8.985
23	620	64	2.718	105	5.258	146	7.662	187	8.989
24	660	65	2.777	106	5.320	147	7.714	188	8.992
25	701	66	2.837	107	5.383	148	7.766	189	8.994
26	742	67	2.897	108	5.445	149	7.817	190	8.995
27	785	68	2.957	109	5.507	150	7.868		
28	828	69	3.017	110	5.569	151	7.918		
29	871	70	3.077	111	5.631	152	7.967		
30	916	71	3.138	112	5.693	153	8.016		
31	961	72	3.198	113	5.755	154	8.065		
32	1.006	73	3.259	114	5.817	155	8.113		
33	1.053	74	3.321	115	5.878	156	8.160		
34	1.099	75	3.382	116	5.939	157	8.207		
35	1.147	76	3.443	117	6.001	158	8.253		
36	1.195	77	3.505	118	6.061	159	8.299		
37	1.243	78	3.567	119	6.122	160	8.344		
38	1.292	79	3.629	120	6.183	161	8.388		
39	1.342	80	3.691	121	6.243	162	8.432		
40	1.392	81	3.753	122	6.303	163	8.475		

I DATI RIPORTATI SONO TEORICI E POSSONO VARIARE DI $\pm 4\%$; IN OGNI CASO LA LORO ATTENDIBILITÀ DIPENDE DALLA CORRETTA POSA IN OPERA DEL SERBATOIO, CHE DEVE ESSERE INSTALLATO PERFETTAMENTE ORIZZONTALE.

**EMILIANA
SERBATOI**
Largo Maestri del Lavoro, 40
41011 CAMPOGALLIANO (MO)
Tel. 059-521911 Fax 059-521919
Partita IVA 01499200366

