



NORTHERN TANK INSPECTIONS LTD.

(Visual/Internal/Leak/Pressure/Thickness)

Owner	Advance Group Ltd	Date	March 23/2024
Address	7209 99st	Manufacturer	CompTank
	Peace River AB. T8S 1B3	Mfr. Serial No.	2C9LTA001DB075668
Phone Number	780-617-4031	Tank Spec:	TC 412
Unit No.	03-35	M.A.W.P.	35 Psi kPa/psi

EXTERNAL VISUAL INSPECTION CHECKLIST/INSPECTION REPORT

Item	Activity	Complies	Needs Repair	See Remarks
1	Data plate: tank attachment - entries legible - no paint - corrosion	X		
2	Shell and heads: condition of welds - dents - gouges - corrosion or abrasion	X		
3	Tank wall thickness: checked in accordance with Ultrasonic Thickness Testing Checklist/Inspection Report	X		
4	Upper coupler assembly: condition of plate - corrosion, deformation, and lubrication - bolt tightness - king pin wear and deformation (drop and service plate if necessary)	NA		
5	Void areas: signs of corrosion - fittings and drains unplugged and operable	NA		
6	Bolted attachments: piping brackets and supports - valve installations - valve operator installation - dust cap retainers - all tank-to frame and/or undercarriage attachments	X		
7	Piping and all valves and adapters: attachments - leakage - handles and levers - cables or air lines - shear sections - dust caps - all gaskets or O-rings - lubrication points	X		
8	For tanks that carry corrosive lading to the valves, all reclosing pressure relief valves shall either be: ☐ replaced, or ☐ tested to ensure they open at the required set-to-discharge pressure for the tank's MAWP and re-seated to a leak-tight condition at not less than 90% of that pressure, or the reseal pressure prescribed for the tank specification	X		
9	Internal valve operation: three means of closure (normal, remote, and thermal) - function check - cable adjustment - condition of cables and pulleys - interconnection with load/unload vents - fusibles - brake interlocks - lubrication points	X		
10	Ladders, catwalks and platforms: attachments to tank - tightness of bolts - deformation of structures - ground clearance	X		
11	Manhole assembly area (for each compartment): evidence of leakage - warpage, corrosion, and impact damage to dome and filler covers, weld collar, gasket seal surfaces, overturn protection structure, clamping ring, and all welds - condition of filler cover and dome gaskets - evidence of product coagulation - condition of latches, hinges, all bolted connections, and drains. If necessary, remove dome cover and subject to 15 psig structural capability test. Enter test results in remarks.	X		
12	Inspect and repair as necessary all parts and accessories	X		
13	Tank marking: Date (month and year), service symbol (V) after all defects corrected, last digits of Northern Tank Inspection's registration number (1190)	X		

4	Tank Marking: Date (month and year) service symbol (T) after all defects are corrected, the last 4 digits of Northern Tank Inspections' TCRN 1190	X		
---	---	---	--	--

Remarks:

Tank Inspector or Tank Tester		Corporate Officer or Manager responsible for compliance	
Signature	Taylor Read Digitally signed by Taylor Read Date: 2020.12.23 12:45:24 +07'00'	Signature	
Print Name	Taylor Read	Print Name	
By:	Northern Tank Inspections Ltd. 1011 Westerra Place Stony Plain, T7Z 2W9 Phone: (780) 497-2975	TCRN: 1190	

12	Loading/unloading vent: close internal valve - relieve pressure in vapour system by opening and closing line relief petcock - monitor gauge to detect any leakage past loading/unloading vent	X		
13	Remote valve operators: open internal valve with normal operator - close with remote operator - open discharge valve and drain piping - check for continued drainage - close discharge valve - open and close internal valve with normal operator, fill piping with water	X		
14	Inspect overall piping system for leakage	X		
15	With all valves close, hold test pressure for 5 minutes for successful test	X		
16	Restore operations of all vents - remove red flags	X		
17	Tank Marking: Date (month and year), service symbol (T) after all defects are corrected, the last 4 digits of Northern Tank Inspections' TCRN 1190	X		

PRESSURE TEST REPORT

Test Pressure:	52.5 Psi
Holding Time at Test Pressure:	20 Min
Results:	Pass
Authorized Inspector Witnessing Test:	Taylor Read/ Ben Stewart

ULTRASONIC THICKNESS TEST CHECKLIST/INSPECTION REPORT

Item	Activity	Complies (QC initial)	Needs Repair	See Remarks
ALL COMPANY TANK ENTRY SAFETY PROCEDURES AND OH&S REGULATIONS MUST BE COMPILED WITH.				
1	Clean, dry, or buff down to bare metal surfaces to be measured.	X		
2	Calibrate the UT instrument.	X		
3	Perform thickness testing on the tank head and shell:	X		
	-Around any piping that retains lading	X		
	-High stress areas of the shell, such as the tank bottom	X		
	-Around openings, weld joints, shell reinforcements, and locations where appurtenances are attached	X		
	-Exterior surfaces of shell and heads: suspect areas in parent metal and along welds - areas around internal valve installations and manhole weld collars - weld pads	X		
	-Fifth wheel upper coupler assembly: upper coupler and vertical framing			
	-Suspension system attachments and connecting structures: longitudinal frames - bolsets - gussets	X		
	-Known thin areas: Identified in prior inspection tests	X		
	-Internal compartment surfaces: along product level lines - around splash deflectors - around valve sumps - along tank bottom	X		
	-Any structures joining multiple carbon steel tanks on a self-supporting transport unit	X		

INTERNAL VISUAL INSPECTION CHECKLIST/INSPECTION REPORT

Item	Activity	Complies	Needs Repair	See Remarks
ALL COMPANY TANK ENTRY SAFETY PROCEDURES AND OH&S REGULATIONS MUST BE COMPILED WITH				
1	Structure: Inspect for corrosion, abrasion, dents, pitting, or distortion at manhole area - around valve or drain sumps and splash deflectors - look for discoloration and bleeding - inspecting all structures for deformation - special attention to structure above upper coupler. (Identify in remarks all dents, gouges, or other abnormal surface changes, whether or not repairs are required.) (Mark any areas that require UT testing and identify in remarks.)	X		
2	Tank wall thickness verified in accordance with Ultrasonic Thickness Testing Checklist/Inspection Report	X		
3	Welds: check every inch of every weld in tank, making hand contact where possible - special attention to bulkhead and baffle welds - special attention to welds in stress area such as above fifth wheel upper coupler	X		
4	Piping and Valves: Check installation tightness - check poppet travel and make visual inspection of valves surfaces - clear and make sure all screens - check for foreign matter in valves sumps - check mechanical linkages between valves and load/unload vents	X		
5	Tank marking: Date (month and year), service symbol (1) after all defects corrected, last digits of Northern Tank Inspection's registration number (1190)	X		

HYDROSTATIC LEAK TEST CHECKLIST/INSPECTION REPORT

Item	Activity	Complies (QCI initial)	Needs Repair	See Remarks
Procedure must be completed for each compartment - Inert and red flag all vents that function at less than test pressure				
1	Close all valves and fill tank with water or other liquid having similar properties at a temperature not exceeding 38°C (100°F), with filler cover open. Check all surfaces for leaks. Checks all top and bottom component installations below water line for leaks - cleanouts - welds - vents - valve sumps	X		
2	Internal valve: open discharge valves - check for leaks - close discharge valve	X		
3	Discharge valves: Open internal valves, fill piping with water - check for leaks - close internal valves	X		
4	Install pressure gauge and line relief petcock on vapour recovery return line adapter	X		
5	In accordance with Northern Tank Inspections' safety manual, set pressure manifold to just above the test pressure required for the tank being worked on	X		
6	Close all tanks openings and valves, and then apply pressure at top of tank as is noted in Table 4.1 of TC Procedure, or Table 7.3 of B620	X		
7	Check all piping and accessories at not less than 80% of MAWP	X		
8	Check all surfaces and component installations for leaks - particular attention in manhole assembly area	X		
9	Internal valves: open discharge valves and drain piping - check for continued drainage - close discharge valve	X		
10	Discharge Valves: Open internal valves, fill piping with water - check for leaks - close internal valvesleakage from discharge valve	X		
11	Vapor recovery system: check for leaks around hood and all components under pressure	X		