

R04-4  
Jun



1791 30th St. S.W.  
Medicine Hat, AB T1B 3N5  
Phone: (403) 527-7272  
Fax: (403) 529-6526  
Facility Registration No. 25-0709

### Inspection Report in Accordance with CSA B620-20

TEST DATE: May 4, 2026

TANK OWNER: Rafter 9 Oilfield Service Ltd  
ADDRESS: PO Box 550 Stn Main Brooks Alberta T1R 1B5

|   |  |                             |
|---|--|-----------------------------|
| TELEPHONE: 403 501-1660   | SERIAL NO.: CF41524  |                             |
| UNIT NO.: T11   | MVID/TCRN:   |                             |
| MANUFACTURER: Lazer Inox  | ASSEMBLER: Lazer Inox  |                             |
| TC SPEC.: 407   | MATERIAL: SA240-316  | CERTIFICATION DATE: 08/2014 |
| MINIMUM THICKNESS SHELL: 3.28 mm  | MINIMUM THICKNESS HEAD: 4.03 mm  |                             |
| MAWP: 25 psi  | DESIGN PRESSURE:   |                             |
| LINING: YES <input type="checkbox"/> NO <input checked="" type="checkbox"/> | INSULATED: YES <input type="checkbox"/> NO <input checked="" type="checkbox"/> |                             |
| SPECIAL SERVICE CONDITIONS:   |  |                             |

|                 |            |   |   |
|-----------------|------------|---|---|
| COMP. CAPACITY: | 1 22,000 L | 2 | 3 |
|                 | 4          | 5 |   |

INSPECTION PERFORMED V  I  P  K  T  UC  L

PRESSURE RELIEF DEVICES: SET TO DISCHARGE PRESSURE:

|   |                                   |                                   |                    |
|---|-----------------------------------|-----------------------------------|--------------------|
| #1) TYPE: Fort Vale                             | SERIAL NO: 0558602                | OPEN PSI: 30 psi                  | RESEAT PSI: 30 psi |
| REINSTALLED <input checked="" type="checkbox"/> | REPAIRED <input type="checkbox"/> | REPLACED <input type="checkbox"/> |                    |
| #2) TYPE: Fort Vale                             | SERIAL NO: 0559883                | OPEN PSI: 30 psi                  | RESEAT PSI: 30 psi |
| REINSTALLED <input checked="" type="checkbox"/> | REPAIRED <input type="checkbox"/> | REPLACED <input type="checkbox"/> |                    |
| #3) TYPE:                                       | SERIAL NO:                        | OPEN PSI:                         | RESEAT PSI:        |
| REINSTALLED <input type="checkbox"/>            | REPAIRED <input type="checkbox"/> | REPLACED <input type="checkbox"/> |                    |
| #4) TYPE:                                       | SERIAL NO:                        | OPEN PSI:                         | RESEAT PSI:        |
| REINSTALLED <input type="checkbox"/>            | REPAIRED <input type="checkbox"/> | REPLACED <input type="checkbox"/> |                    |
| #5) TYPE:                                       | SERIAL NO:                        | OPEN PSI:                         | RESEAT PSI:        |
| REINSTALLED <input type="checkbox"/>            | REPAIRED <input type="checkbox"/> | REPLACED <input type="checkbox"/> |                    |

**TC 331, MC 331, MC 330, TC 51, CTC 51, DOT 51 TANKS:**

CONSTRUCTED OF QUENCHED AND TEMPERED STEEL: QT YES  NO

CONSTRUCTED OF OTHER THAN QUENCHED AND TEMPERED STEEL: NQT YES  NO


TANK STRESS RELIEVED AFTER MANUFACTURE: YES  NO

TANK STRESS RELIEVED AFTER REPAIR: YES  NO

TANK STRESS RELIEF AFTER REPAIR: COMPLETE:  LOCAL:  N/A

RECORD ALL INFORMATION FROM DATA PLATE AND TAKE PHOTOS OF DATA PLATE AND UNIT FOR FILE:

**EXTERNAL VISUAL INSPECTION "V"**

| Item Inspected   | QC Man.Ref.  | Complies | Reject            | Retest Complies |
|--|--|----------|-------------------|-----------------|
| Data plate, present and legible  | 12.2.3   | X        |                   |                 |
| Shell & heads; corrosion, dents, overlay patches, leaks, voids, etc.     | 12.2.4   | X        |                   |                 |
| Structural members, outriggers crossmembers, etc.                        | 12.2.5   | X        |                   |                 |
| Upper coupler for cracks, corrosion, distortion, and bolt tightness      | 12.2.6   | N/A      |                   |                 |
| Piping and valves for leakage, damage, and corrosion                     | 12.2.7   | X        |                   |                 |
| Valve operating systems, remote closures, and thermal devices            | 12.2.7   | X        |                   |                 |
| Hoses for defects, identification and test dates                         | 12.2.8   |          | X                 | X               |
| Gaskets on full opening rear heads for damage or cuts                    | 12.2.9   | N/A      |                   |                 |
| Tank attachments to frame or running gear                                | 12.2.10  | X        |                   |                 |
| Ladders, walkways, platforms, etc.                                       | 12.2.11  | X        |                   |                 |
| Fill covers, manways, and closure devices                                | 12.2.12  | X        |                   |                 |
| Relief valves and vents (replace or test if In corrosive lading Service) | 12.2.13  | X        |                   |                 |
| Accident damage protection; compliance, damage, distortion, corrosion    | 12.2.14  | X        |                   |                 |
| Off truck emergency shut down system                                     | 12.2.15  | X        |                   |                 |
| Inspector: Dan Laekeman  | Signature:  |          | Date: May 4, 2026 |                 |

**INTERNAL VISUAL INSPECTION "I"**

| Item Inspected  | QC Man Ref. | Complies | Reject | Retest Complies |
|---|-------------|----------|--------|-----------------|
| Interior surface for corrosion, distortion, overlay patches, cracking, etc.   | 12.3.2      |          |        |                 |
| If required by the tank specification perform Wet Fluorescent Magnetic Particle Inspection and file report in accordance with Dynamic Industrial Solutions Procedure Number QP-16 | 12.3.3      |          |        |                 |
| Interior welds for defects, cracking, etc.  | 12.3.4      |          |        |                 |
| Internal supports and attachments   | 12.3.5      |          |        |                 |
| Internal valves, piping and vents for leakage, damage, etc.   | 12.3.5      |          |        |                 |
| Inspector:  | Signature:  |          | Date:  |                 |

**Rejection Criteria for Visual Inspections**

**Any of the following conditions shall cause the tank to be rejected:**

- Less than minimum material thickness under any cut, dig or gouge
- Any dent with depth greater than 1/2" where it includes a weld
- Any dent with a depth greater than 10 % of the length of the dent
- Any weld defect including a crack, pinhole, or incomplete fusion of the weld
- Any structural defect or any source of leakage or any repairs made using overlay patches
- Defective, unidentified or out of test hose assemblies

**HYDROSTATIC LEAKAGE TEST "K"** (QC Manual Reference 12.4)

Test Pressure: 20 psi


(80% of the MAWP Min.)

Test Medium: Water

Pressure Gauge Serial No.:

21821460039

Calibration Date: Dec. 5, 2025

| Hydrostatic Leakage Test Item   | QC Man.Ref. | Complies   | Reject | Retest Complies   |
|---|-------------|--|--------|-------------------|
| All product piping, valves, and accessories in place. Breathing vents rendered Inoperative.                           | 12.4.2      | X  |        |                   |
| Close al Internals and open all discharge valves.   | 12.4.5      | X  |        |                   |
| Ensure all adjacent compartments and voids are empty and open to atmosphere.  | 12.4.6      | X  |        |                   |
| Fill compartment with enough test medium to cover valves.   | 12.4.7      | X  |        |                   |
| Pressurize tank to correct pressure and hold for 5 min. (Must have 0 psi pressure drop).                              | 12.4.8      | X  |        |                   |
| While under pressure check tank, gaskets, internal valves, manhole covers, and vents for leakage.                     | 12.4.9      | X  |        |                   |
| Close discharge valves and open internal valves. Adjust pressure and check plumbing and discharge valves for leakage. | 12.4.10     | X  |        |                   |
| Restore operation of all vents.   | 12.4.12     | X  |        |                   |
| Tester: Dan Laekeman  |             | Signature:  |        | Date: May 4, 2026 |

**HYDROSTATIC PRESSURE TEST "P"** (QC Manual Reference 12.5)

Test Pressure (Tank):

(Refer to Table 7.4 of CSA B620-20 posted in fitting cabinet for appropriate test pressure)

Test Pressure (Piping):

(80% of the MAWP)

Test Medium: -

Pressure Gauge Serial No.:

Calibration Date:

| Hydrostatic Pressure Test Item  | QC Man Ref.  | Complies   | Reject | Retest Complies |
|---|--------------|------------|--------|-----------------|
| Level and adequately support the tank.  | 12.5.1.3     |            |        |                 |
| Remove self closing relief valves for testing.  | 12.5.1.4     |            |        |                 |
| Remove or render Inoperative all other relief devices and close internal valves.  | 12.5.1.5     |            |        |                 |
| Ensure all remaining closures are rated at or above test pressure.  | 12.5.1.6     |            |        |                 |
| Ensure adjacent compartments and voids are empty and open to atmosphere.  | 12.5.1.7     |            |        |                 |
| Fill compartment completely with water.   | 12.5.2.1     |            |        |                 |
| Install pressurization line and slowly increase pressure to test pressure.  | 12.5.2.2 & 3 |            |        |                 |
| Disconnect pressure source and hold pressure for 10 minutes.  | 12.5.2.4     |            |        |                 |
| With tank under pressure inspect exterior for leaks, defects, or distortion.  | 12.5.2.5     |            |        |                 |
| Relieve pressure in tank.   | 12.5.2.6     |            |        |                 |
| Close discharge valves and open Internals. Pressurize tank to 80% of the MAWP. Hold for 10 minutes and check plumbing and discharge valves for leaks. | 12.5.2.7     |            |        |                 |
| Relieve pressure and drain tank.  | 12.5.2.9     |            |        |                 |
| Reinstall or return all relief valves to working condition.   | 12.5.2.10    |            |        |                 |
| Tester:   |              | Signature: |        | Date:           |

**PNEUMATIC LEAKAGE TEST "K"** (QC Manual Reference 12.4)

Test Pressure: (80% of the MAWP Min.)

Test Medium:

Pressure Gauge Serial No.:

Calibration Date:

| Pneumatic Leakage Test Item   | QC Man.Ref. | Complies         | Reject | Retest Complies |
|---|-------------|------------------|--------|-----------------|
| All product piping, valves, and accessories in place. Breathing vents rendered inoperative.                           | 12.4.2      |                  |        |                 |
| Close all internals and open all discharge valves.  | 12.4.5      |                  |        |                 |
| Ensure all adjacent compartments and voids are empty and open to atmosphere.  | 12.4.6      |                  |        |                 |
| Fill compartment with enough test medium to cover valves.   | 12.4.7      |                  |        |                 |
| Pressurize tank to correct pressure and hold for 5 min. (Must have 0 psi pressure drop).                              | 12.4.8      |                  |        |                 |
| While under pressure check tank, gaskets, internal valves, manhole covers, and vents for leakage.                     | 12.4.9      |                  |        |                 |
| Close discharge valves and open internal valves. Adjust pressure and check plumbing and discharge valves for leakage. | 12.4.10     |                  |        |                 |
| Relieve pressure in tank and restore operation of all vents.  | 12.4.12     |                  |        |                 |
| Tester: _____   |             | Signature: _____ |        | Date: _____     |

NOTE: A pneumatic pressure test, with the concurrence of the tank owner shall only be performed when there is no suspicion of weakness in the tank and residual water in the tank would adversely react with the lading or the tank, or any lading retention component, or result in the formation of ice causing damage to or adversely affecting the functioning of the tank.

**PNEUMATIC PRESSURE TEST "P"** (QC Manual Reference 12.5)

Test Pressure (Tank):

(Refer to Table 7.4 of CSA B620-20 posted in fitting cabinet for appropriate test pressure)

Test Pressure (Piping): (80% of the MAWP)

Test Medium:

Pressure Gauge Serial No.:


Calibration Date:

| Pneumatic Pressure Test Item   | QC Man Ref.       | Complies         | Reject | Retest Complies |
|--|-------------------|------------------|--------|-----------------|
| Level and adequately support the tank.   | 12.5.1.3          |                  |        |                 |
| Remove self closing relief valves for testing.   | 12.5.1.4          |                  |        |                 |
| Remove or render inoperative all other relief devices and close internal valves.   | 12.5.1.5          |                  |        |                 |
| Ensure all remaining closures are rated at or above test pressure.   | 12.5.1.6          |                  |        |                 |
| Ensure adjacent compartments and voids are empty and open to atmosphere.   | 12.5.1.7          |                  |        |                 |
| Advise all personnel that a pneumatic test is being performed and that they must stay clear of the tank being tested.  | 12.5.3.2          |                  |        |                 |
| Apply pressurization line and slowly increase pressure in tank. Pressure to one half the test pressure then increase by 1/10 of test pressure until pressure is reached. | 12.5.3.3-12.5.3.5 |                  |        |                 |
| Hold pressure for 10 minutes, then reduce it to the MAWP.  | 12.5.3.6          |                  |        |                 |
| Maintain pressure while using soap and water to coat entire surface of all joints and around all venting and piping.   | 12.5.3.7          |                  |        |                 |
| Relieve pressure in tank, close discharge valves and open internal valves.   | 12.5.3.8 & 9      |                  |        |                 |
| Re pressurize tank to 80 % of the MAWP and hold for 10 min. Soap surface of all joints and connections in the section of plumbing being tested.                          | 12.5.3.10 & 11    |                  |        |                 |
| Relieve pressure in tank.  | 12.5.3.12         |                  |        |                 |
| Reinstall or return to working condition all relief devices.   | 12.5.3.14         |                  |        |                 |
| Tester: _____  |                   | Signature: _____ |        | Date: _____     |


**THICKNESS TEST "T"** (QC Manual Reference 12.6)

|           |              |             |             |             |             |
|-----------|--------------|-------------|-------------|-------------|-------------|
|           | <b>12:00</b> | <b>3:00</b> | <b>6:00</b> | <b>9:00</b> | <b>HEAD</b> |
| <b>1</b>  |              |             |             |             | <b>1</b>    |
| <b>2</b>  |              |             |             |             | <b>2</b>    |
| <b>3</b>  |              |             |             |             | <b>3</b>    |
| <b>4</b>  |              |             |             |             | <b>4</b>    |
| <b>5</b>  |              |             |             |             | <b>5</b>    |
| <b>6</b>  |              |             |             |             | <b>6</b>    |
| <b>7</b>  |              |             |             |             | <b>7</b>    |
| <b>8</b>  |              |             |             |             | <b>8</b>    |
| <b>9</b>  |              |             |             |             | <b>9</b>    |
| <b>10</b> |              |             |             |             | <b>10</b>   |
| <b>11</b> |              |             |             |             | <b>11</b>   |
|           |              |             |             |             | <b>HEAD</b> |
|           | <b>12:00</b> | <b>3:00</b> | <b>6:00</b> | <b>9:00</b> |             |


**FRONT HEAD**




**REAR HEAD**




**MANWAY**




**SUMP**



**NOZZLE**



**NOZZLE**



Manufacture's Thickness: Head: \_\_\_\_\_ Shell: \_\_\_\_\_  
 Minimum Thickness: Head: \_\_\_\_\_ Shell: \_\_\_\_\_

|                         |                         |                    |
|-------------------------|-------------------------|--------------------|
| <b>Inspector:</b> _____ | <b>Signature:</b> _____ | <b>Date:</b> _____ |
|-------------------------|-------------------------|--------------------|

**HEATING SYSTEM TEST** (QC Manual Reference 12.10)

Test Pressure \_\_\_\_\_

Test Medium: \_\_\_\_\_

Pressure Gauge Serial No.: \_\_\_\_\_

Calibration Date: \_\_\_\_\_

| Heating System Test Inspection Item   | QC Man.Ref. | Complies | Reject | Retest Complies |
|---|-------------|----------|--------|-----------------|
| Ensure all tank compartments are empty and at atmospheric pressure                  | 12.10.1     |          |        |                 |
| Fill heating system with fluid and pressurize to 1.5 times the heating systems MAWP | 12.10.2     |          |        |                 |
| Hold test pressure for 5 min. And inspect for internal and external leakage         | 12.10.3     |          |        |                 |
| If equipped with flues, inspect for product leakage into flues                      | 12.10.4     |          |        |                 |

|                         |                         |                    |
|-------------------------|-------------------------|--------------------|
| <b>Inspector:</b> _____ | <b>Signature:</b> _____ | <b>Date:</b> _____ |
|-------------------------|-------------------------|--------------------|





1791 30<sup>th</sup> St. S.W.  
Medicine Hat, AB T1B 3N5  
Phone: (403) 527-7272  
Fax: (403) 529-6526

### Hose Test and Inspection Certificate

**This is to certify that the following hose has been inspected and tested to the standards detailed by CSA B620-20.**

Customer: Rafter 9 Oilfield Services Ltd.  
Test Date: May 4, 2026  
Job No: 7721  
Unit: T11

Equipment

| Hose Serial # | Visual Inspection Pass/Fail | HAWP    | Hose Test Pressure | Hose test done in accordance with B620 Pass/Fail | Hose marked in accordance with B620 Yes/No |
|---------------|-----------------------------|---------|--------------------|--|--|
| 05 26 T11     | Pass                        | 250 psi | 250 psi            | Pass   | Yes  |
|               |                             |         |                    |  |  |
|               |                             |         |                    |  |  |
|               |                             |         |                    |  |  |
|               |                             |         |                    |  |  |
|               |                             |         |                    |  |  |
|               |                             |         |                    |  |  |
|               |                             |         |                    |  |  |
|               |                             |         |                    |  |  |


Comments:

Tester: Dan Laekeman

Signature: 

Date: May 4, 2026

Inspector: Dan Laekeman

Signature: 

Date: May 4, 2026