

EV41-1

CARIBOU ELECTRIC

GENERATOR LOAD TEST

Wo#	Date	Customer	Model#	Serial #	Kw size	Voltage
41642	JUNE 16/25	tech	WFS	DF027012	20	480

Time	Hertz	Amps A	Amps B	Amps C	Volts AB	Volts BC	Volts CA	KW load	Water temp	Oil pressure	DC volts
11:50	60	2.5	2.3	2.5	4.80	4.80	4.80	2.1	179	47	14.2
12:00	60	5.0	5.0	5.0	4.80	4.80	4.80	4.9	180	45	14.2
12:10	60	8.0	8.2	8.3	4.80	4.80	4.80	8.8	180	45	14.2
12:20	60	10.4	10.4	10.4	4.80	4.80	4.80	8.6	180	45	14.2
12:30	60	12.7	12.1	12.4	4.80	4.80	4.80	13.5	180	45	14.2
12:40	60	15.5	15.6	15.6	4.80	4.80	4.80	15.5	180	44	14.2
12:50	60	2.0	2.0	2.0	4.80	4.80	4.80	19.1	182	43	14.2
1:00	60	2.5	2.3	2.5	4.80	4.80	4.80	22.4	182	42	14.2
1:30	60	2.5	2.3	2.5	4.80	4.80	4.80	22.4	182	42	14.2

Notes

MODEL H 100A 2555/445 SER. # 7156906
CHARGE 120/208 VOLTS 4 L40/120 WATT OUT PUT
CHARGE 600 WATT OUT PUT
CHARGE 138A 250 A.C. METERS - BLOCK LOADED AT 50%
FUNNO SCREWDRIVER TAMMED INTO WIRING HARNESS



NEWAGE | STAMFORD | AVK marathon