



2026214 Y01/14 Lot 4256

FBR Inc Complete Dispersal September 22, 2026

All light towers, generators, engines use Napa Gold or WIX premium air, oil, fuel filters. All units use Shell Rotella T6 5-40 SAE full synthetic motor oil, oil changed max 500 hours and many routinely changed 300-400 hours to accommodate schedule. Maintenance performed by FBR shop, field team, Westquip Diesel Sales Ltd Calgary or Western Generator Sales Airdrie.

Unit GS 5 Engine 4LE2 #260 227

November 2024 @ 10,562 hours- repalced crank seal

April 2025 @10,967 hours – rebuilt top end, cam shaft, pumps, lifters