



2026214 Y01/18 Lot 906

FBR Inc Complete Dispersal September 22, 2026

All light towers, generators, engines use Napa Gold or WIX premium air, oil, fuel filters. All units use Shell Rotella T6 5-40 SAE full synthetic motor oil, oil changed max 500 hours and many routinely changed 300-400 hours to accommodate schedule. Maintenance performed by FBR shop, field team, Westquip Diesel Sales Ltd Calgary or Western Generator Sales Airdrie.

Unit LT18 - Mitsubishi Engine

May 2023 – Install vertical mast w LED lights- Westquip @ 12,672 hours

October 2024 - New battery