



2026214 Y01/28 Lot 931

FBR Inc Complete Dispersal September 22, 2026

All light towers, generators, engines use Napa Gold or WIX premium air, oil, fuel filters. All units use Shell Rotella T6 5-40 SAE full synthetic motor oil, oil changed max 500 hours and many routinely changed 300-400 hours to accommodate schedule. Maintenance performed by FBR shop, field team, Westquip Diesel Sales Ltd Calgary or Western Generator Sales Airdrie.

Unit GS 10

July 2024 – new electric fan