



2026214 Y01/34 Lot 912

FBR Inc Complete Dispersal September 22, 2026

All light towers, generators, engines use Napa Gold or WIX premium air, oil, fuel filters. All units use Shell Rotella T6 5-40 SAE full synthetic motor oil, oil changed max 500 hours and many routinely changed 300-400 hours to accommodate schedule. Maintenance performed by FBR shop, field team, Westquip Diesel Sales Ltd Calgary or Western Generator Sales Airdrie.

Unit LT17 - Isuzu Engine 4LE2

January 2024 – Vertical mast installed by Westquip

February 2025 – Battery replaced @ 15,790 hours

February 2026 – Crank seal replaced @ 18,028 hours