



2026214 Y01/39 Lot 899

FBR Inc Complete Dispersal September 22, 2026

All light towers, generators, engines use Napa Gold or WIX premium air, oil, fuel filters. All units use Shell Rotella T6 5-40 SAE full synthetic motor oil, oil changed max 500 hours and many routinely changed 300-400 hours to accommodate schedule. Maintenance performed by FBR shop, field team, Westquip Diesel Sales Ltd Calgary or Western Generator Sales Airdrie.

Unit LT15 - Isuzu Engine 4LE2

November 2019 – Governor replaced @ 7,160 hours

September 2021 – Generator replaced @ 9,847 hours

July 2022 – Crank seal replaced @ 12,217 hours

April 2026 – Fan belt replaced @ 27,860 hours