



2026214 Y01/41 Lot 902

FBR Inc Complete Dispersal September 22, 2026

All light towers, generators, engines use Napa Gold or WIX premium air, oil, fuel filters. All units use Shell Rotella T6 5-40 SAE full synthetic motor oil, oil changed max 500 hours and many routinely changed 300-400 hours to accommodate schedule. Maintenance performed by FBR shop, field team, Westquip Diesel Sales Ltd Calgary or Western Generator Sales Airdrie.

Unit LT10 - Isuzu Engine 4LE2

November 2021 – Injectors removed & cleaned, valves reset, compression test, load banked @10,912 hours

October 2022 – Water pump replaced @12,975 hours

December 2022 – Crank seal replaced @13,395 hours

May 2023 – Reset valves @ 14,378 hours

February 2025 – Crank seal replaced @ 19,351 hours