



2026214 Y01/43 Lot 897

FBR Inc Complete Dispersal September 22, 2026

All light towers, generators, engines use Napa Gold or WIX premium air, oil, fuel filters. All units use Shell Rotella T6 5-40 SAE full synthetic motor oil, oil changed max 500 hours and many routinely changed 300-400 hours to accommodate schedule. Maintenance performed by FBR shop, field team, Westquip Diesel Sales Ltd Calgary or Western Generator Sales Airdrie.

Unit LT16 - Isuzu Engine 4LE2

May 2023 – Water pump replaced @ 15,802 hours

May 2024 – Crank Seal replaced @ 20,550 hours

May 2026 – Battery replaced @ 26,742 hours