



2026214 Y01/50 Lot 903

FBR Inc Complete Dispersal September 22, 2026

All light towers, generators, engines use Napa Gold or WIX premium air, oil, fuel filters. All units use Shell Rotella T6 5-40 SAE full synthetic motor oil, oil changed max 500 hours and many routinely changed 300-400 hours to accommodate schedule. Maintenance performed by FBR shop, field team, Westquip Diesel Sales Ltd Calgary or Western Generator Sales Airdrie.

Unit LT13 - Isuzu Engine 4LE2

January 2018 – Crank seal replaced @ 2,238 hours

November 2021 – Set valves @ 9,805 hours

November 2023 – Governor replaced @ 16,325 hours

September 2025 – Battery replaced @ 23,329 hours