



2026214 Y01/52 Lot 889

FBR Inc Complete Dispersal September 22, 2026

All light towers, generators, engines use Napa Gold or WIX premium air, oil, fuel filters. All units use Shell Rotella T6 5-40 SAE full synthetic motor oil, oil changed max 500 hours and many routinely changed 300-400 hours to accommodate schedule. Maintenance performed by FBR shop, field team, Westquip Diesel Sales Ltd Calgary or Western Generator Sales Airdrie.

Unit LT21 – 20kW – Isuzu Engine 4LE2

December 2021 – Valve set, injectors cleaned – Westquip @ 7,747 hours

August 2023 – Crank seal replaced @ 10,448 hours