



2026214 Y01/54 Lot 883

FBR Inc Complete Dispersal September 22, 2026

All light towers, generators, engines use Napa Gold or WIX premium air, oil, fuel filters. All units use Shell Rotella T6 5-40 SAE full synthetic motor oil, oil changed max 500 hours and many routinely changed 300-400 hours to accommodate schedule. Maintenance performed by FBR shop, field team, Westquip Diesel Sales Ltd Calgary or Western Generator Sales Airdrie.

Unit LT22 – 20kW – Isuzu Engine 4LE2

October 2022 – Governor replaced, injector pump shims replaced - Westquip @ 8,172 hours

August 2023 – Crank seal replaced @ 9,105 hours

November 2024 – Fan, water pump & RAD replaced @ 10,910 hours