



2026214 Y01/55 Lot 882

FBR Inc Complete Dispersal September 22, 2026

All light towers, generators, engines use Napa Gold or WIX premium air, oil, fuel filters. All units use Shell Rotella T6 5-40 SAE full synthetic motor oil, oil changed max 500 hours and many routinely changed 300-400 hours to accommodate schedule. Maintenance performed by FBR shop, field team, Westquip Diesel Sales Ltd Calgary or Western Generator Sales Airdrie.

Unit LT23 – 20kW – Isuzu Engine 4LE2

December 2022 – Crank seal replaced @ 10,251 hours

May 2025 – Valve set, inspect cam shaft, injector pump replaced @ 11,734 hours