

PERMIT TO OPERATE

A Drinking Water System with 1 Public Connection

System Name: **Fort St John Water Inc. - Unit #117**

Fort St John Water Inc.

Physical Location :

11650 Maclean Road

Fort St. John BC

Owner Name: **George Bergen**

Conditions of Permit

- > Maintain a minimum of one water bacteriology sample every month during the operational season, unless the Environmental Health Officer requests a greater frequency.
- > Maintain an up-to-date Emergency Response Plan.
- > Maintain a minimum free chlorine residual of 0.2 ppm throughout the distribution system and ensure the minimum is met upon delivery.
- > Operator must successfully complete the Environmental Operators Certification Program - Small Water System course or equivalent as acceptable by the Drinking Water Officer.
- > Clean, disinfect and flush cistern at least on an annual basis.
- > Haul potable water only from a Community Water Source with a Drinking Water Operating Permit that is not under a Boil Water or Do Not Use Water Notice.
- > Maintain an activity log and keep it available for inspection.

17-Aug-2015
Effective Permit Date

Vanessa (p)
Environmental Health Officer