Alberta

VESSEL (A): 2850946
DATE OF INSPECTION: 2026 May 14
DATE OF ISSUANCE: 2026 Jun 05

ABSA
the pressure equipment safety authority

Certificate of Inspection Permit

Pressure Equipment Safety Regulation Section 33

IGNITE OILFIELD SERVICES LTD

51216 RANGE ROAD 214

SHERWOOD PARK, AB
T8E 1G9

Next Inspection Due Date: 2027 May 14
Max. Inspection Interval: 1.00Yr
Year Built: 1994
CRN: M1012.2
Serial #: 7526
Volume:
Heating Surface: 18.58 M2
Surface Area:

89

COMPANY CODE:
DESCRIPTION: HIGH PRESSURE FIRETUBE BOILER
LOCATION: PORTABLE, SHERWOOD PARK
MANUFACTURER: WILLIAMS & DAVIS BOILERS INC

Pressure Relief Valves

PART	MAX. ALLOWABLE PRESSURE	MAX. TEMP	MIN. TEMP	VALVE ID	SETTING	CAPACITY	LOCATION
BOILER	1034 KPA	186 C		SV1	1034 KPA	1191 KG/H	BOILER

At the time of inspection the item described on the Certificate of Inspection Permit was found to comply with the requirements set forth in the Pressure Equipment Safety Regulation and appeared suitable for operation.

Terms and Conditions:

Blow down low water fuel cut-off weekly to test operation.

Test water column and gauge glass daily.

Maintain proper water treatment.

The boiler should be blown down regularly.

Boiler log books should be maintained for all plants and are mandatory for plants that require to be supervised, in accordance with the Power Engineers Regulation, by an individual holding a 5th class/SBO or higher Power Engineering Certificate of Competency.

Owner to ensure all valves and flexible hoses are rated for steam service and inspected regularly for damage prior to operation.

Recommend boiler fuel valves and controls be checked and serviced regularly.

Owner must ensure this vessel/boiler, its overpressure protection devices, pressure gauges and regulating or controlling devices are maintained in good working order and operated safely.

An owner or vendor must notify the Administrator in writing when the pressure equipment identified on this certificate is sold or otherwise disposed.

The owner or person in charge shall report all unsafe conditions, accidents and fires involving Pressure Equipment to the district Safety Codes Officer immediately and shall send a full report in writing to the Administrator as required by the Act. No repairs or alterations may be made unless authorized by a Safety Codes Officer.

Permit issued by: LI, JIN

Alberta Boilers Safety Association
ABSA
Jin Li
NB 16575 AB-467
D00009640
Safety Codes Officer

Signature:

Pursuant to Section 44 of the Safety Codes Act, the item described in this Certificate of Inspection Permit is authorized to operate in the Province of Alberta within the operating limits established herein, provided all terms and conditions detailed in this Permit have been satisfied.

TECHNICAL SAFETY BC

Operating Permit Number: BPV-1686048-2024
(When inquiring always refer to this number.)
Expiry Date: July 31, 2027

BOILER, PRESSURE VESSEL or REFRIGERATION OPERATING PERMIT

August 31, 2026 THERMAL FLUID & STEAM BOILER

GRANTED TO:

Ignite Oilfield Services Ltd.
51216 RANGE ROAD 214
SHERWOOD PARK AB T8E 1G9

SITE ADDRESS

WILLIAMS & DAVIS, SERIAL# 7526
OIL WELL SITES BC V1J 4H9

UNIT IDENTIFICATION

Manufacturer: Williams & Davis Boilers, Inc
Serial No.: 7526
Model:
Unit Name: IOS# 89

Unit No.	Unit Class	CRN No.	MAWP	MAWT	Variance
BPV-089169	High Pressure Steam Boiler	M1012.2(VAR335)	150		No

Your permit application has been assessed. For information about your roles and responsibilities as an asset owner and to learn about Technical Safety BC's Resource Allocation Program (RAP), visit https://www.technicalsafetybc.ca/regulatory-resources/regulatory-notices.

Emerson Automation Solutions Final Control US LP
3950 GREENBRIAR DRIVE
STAFFORD, TX 77477

Certificate of Conformance & Compliance

Date: 02/05/2026

Ship to: SPARTAN CONTROLS LTD
60-11550 BARLOW TRAIL NE
CALGARY T3N 1A7
CANADA

Sold To: SPARTAN CONTROLS LTD
PO Box 6446
CALGARY AB T2P 2E1
CANADA

IOS Unit#89
S/N:0002047Ø

Customer Purchase Order Number	830386078
Emerson Automation Solutions Final Control Order	711390
Applicable ASME Code	SECTION I - STEAM
Customer Information	
Production Order / Lot Number	12525533/000023
Serial Number	SN-000201465 to SN-000201509

Line	Size	Qty.	Customer Part #	EMRN Model / Part #	Set Pressure
23	1 IN	45		6010FEM01AAM	150 PSIG

We hereby certify that the material and items described above are in accordance with Emerson Automation Solutions Final Control (EMRT) specifications and the customer's purchase order as it was acknowledged.

Certified by: _____ Date: 2-10-26

By indication of initials below, we hereby certify that additional, special processes were completed on the above order. These processes were performed in accordance with Emerson Automation Solutions Final Control (EMRT) specifications.

Special Process	Certified By	Date	Special Process (others where applicable)	Certified By	Date
Cleaned for oxygen service in accordance with the cleanliness requirements of ED6304.CGA G4.1.GS-38 & GS-40					
Epoxy coated					
Degreasing					